

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 19/co/ins/2026

Dated: 19/06/2026

It is certified that an inspection team headed by R.K. Singh (Name

of Officers with designation) from U.P.I.N. (Rural) PHED inspected the

C.P. Unique Convent School (Name & Address of the school)
Saidraja Chandrauli

on 19/06/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing

no. RWTL/VNS/047/2627 dated 18/06/26 of

Regional Water Analysis Laboratory U.P. Jal

Migam (Rural) (PHED Lab) certified that

the C.P. Unique Convent School (Name of school) has safe drinking

water facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 01 year

Signature with Seal:

Name : E. Suresh Singh

Designation :

Name & Address of the Office / Department :

To C.P. Unique Convent School
Saidraja Chandrauli
(Name & Address of the Institution)

अधिश्रासी अभियन्ता
खण्ड कार्यालय
उत्तर प्रदेश जल निगम (ग्रामीण)
चन्दौली

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



REGIONAL WATER ANALYSIS LABORATORY, UTTAR PRADESH JAL NIGAM
Bhagwanpur, Varanasi – Uttar Pradesh 221005

*** TEST REPORT ***

Name & Address of Customer: C P UNIQUE CONVENT SCHOOL SHIVAPUR, SAIDRAJA, CHANDALI, UTTAR PRADESH		Customer Reference No.	No: 047/VNS/09 Dated: 18/06/2026
		Sample Submitted by	MR. JAI PRAKASH SINGH
		Date of Sample Receipt	18/06/2026
		Analysis Starting Date	18/06/2026
		Analysis completion Date	18/06/2026
Discipline: Chemical Testing		Group: Water	
Test Report No.:	RWTL/VNS/047/26-27	Date of Issue:	18/06/2026
Registration no.:	RWTL/VNS/2627/REG047	Condition of Sample:	Unsealed
Source:	R O WATER PLANT	Quantity/Type of Bottle:	1000ml / Amber Colored Glass Bottle
Scheme:	NA	Location/Depth:	RO plant C P UNIQUE CONVENT SCHOOL SHIVAPUR, SAIDRAJA, CHANDALI, UTTAR PRADESH / NA
Village:	SHIVAPUR	Habitation:	NA
Block: -	SAIDRAJA	District:	CHANDALI
Latitude:	NA	Longitude:	NA

Sample Type: Treated Water

Sr. No	Parameter	Result	As per 15-10500:2012 (2 nd Rev.)		Unit	Reference Method:
			Acceptable Limit	Permissible Limit		
1	pH	7.90	6.5-8.5	No Relaxation		IS 3025 (Part 11-1993) Electrometric Method
2	Colour	01	5	15	Hazen	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Disagreeable		IS 3025 (Part 5 -2018) (Second Revision)
4	TDS	227	500	"2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	1.34	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	145	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	189	200	600	mg/l	I63025 (Pan 21- 2019) EDTA Method
8	Calcium	88	75	200	mg/l	IS 3025(Part 40-1991) EDTA Titrimetric Method
9	Magnesium	29	30	100	m\$/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	88	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition:

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. * Value not available or test not performed for this parameter.

Ramesh
Dr. Ramesh Yadav
Quality Manager
Authorized Signatory
For, Regional Water Analysis,
Laboratory Jal Nigam Varanasi- UP.

----- End of the Test Report -----